



RIBCO

EXPLOSION PROOF EQUIPMENT

Via dei Mille, 12 - 20061 - ITALY Carugate (MI)
www.ribco.it - info@ribco.it

DECLARATION OF CONFORMITY

Command and signalling units
series RX / RS

IECEX-DCE-CSU-EN

Rev.1 - 2020/04/14

Pag. 1 / 1

DECLARATION OF CONFORMITY

We
RIBCO s.r.l.

Via dei Mille, 12 - 20061 - Carugate (MI) - ITALY

Hereby declare on our own responsibility that the products


**Command and signalling units series
RX / RS / RXI / RSI / RXK / RSK**

Related with this declaration are in conformity of the following international standards:


**IEC 60079-0 : 2017
IEC 60079-1 : 2014-06
IEC 60079-31 : 2013**

IECEX Certificate of Conformity:
IECEX INE 14.0055U


Marking for series RX / RS / RXI / RSI / RXK / RSK

 RIBCO 20061-IT	Mod. <input type="text" value="(1)"/> B/Y: <input type="text" value="(2)"/>	IECEX INE 14.0055U
	Ex db I Mb Ex db IIC Gb (Max Int. Vol=62,9 l)	
	Ex db IIB+H2 Gb (Max Int. Vol=160,6 l)	
	Ex tb IIIC Db IP66	

Marking for series RX / RS / RXI / RSI / RXK / RSK with cylindrical joint less than 26mm

 RIBCO 20061-IT	Mod. <input type="text" value="(1)"/> B/Y: <input type="text" value="(2)"/>	IECEX INE 14.0055U
	Ex db I Mb Ex db IIC Gb (Max Int. Vol=2 l)	
	Ex tb IIIC Db IP66	

Reduced marking for series RX / RS / RXI / RSI / RXK / RSK

 RIBCO 20061-IT	Mod. <input type="text" value="(1)"/> B/Y: <input type="text" value="(2)"/>	IECEX INE 14.0055U
	Ex db / tb	
	IP66	

(1) Code Article

(2) Batch number / Year of construction

CARUGATE (MI), 2020/04/14

Eng. Roberto Borroni
Company Owner
RIBCO s.r.l.

RIBCO s.r.l. a socio unico
